

MAR 1 / 1976

WELL CONSTRUCTOR'S REPORT
FORM 3300-15STATE OF WISCONSIN
DEPARTMENT OF NATURAL RESOURCES
Box 450
Madison, Wisconsin 53701

NOTE

WHITE COPY - DIVISION'S COPY
GREEN COPY - DRILLER'S COPY
YELLOW COPY - OWNER'S COPY

1. COUNTY Ozaukee		CHECK ONE <input checked="" type="checkbox"/> Town <input type="checkbox"/> Village <input type="checkbox"/> City		NAME Cedarburg	
2. LOCATION Section NE Township 10N Range 21E		3. OWNER AT TIME OF DRILLING Bielinski Bros.			
OR - Grid or street no 470		ADDRESS 845 W. College Ave.			
AND - If available subdivision name, lot & block no		POST OFFICE Waukesha			
4. Distance in feet from well to nearest: (Record answer in appropriate block)		BUILDING C I.	SANITARY SEWER C I.	FLOOR DRAIN C I.	FOUNDATION DRAIN SEWER CONNECTED INDEPENDENT
		12			12
CLEAR WATER DRAIN C I.	SEPTIC TANK TILE	PRIVY	SEEPAGE PIT	ABSORPTION FIELD	BARN
	not in			not in	
OTHER POLLUTION SOURCES (Give description such as dump, quarry, drainage well, stream, pond, lake, etc.)					

5. Well is intended to supply water for:


house

6. DRILLHOLE						9. FORMATIONS			
Dia. (in.)	From (ft.)	To (ft.)	Dia. (in.)	From (ft.)	To (ft.)	Kind	From (ft.)	To (ft.)	
10	Surface	20	8	20	42	stoney clay	Surface	27	
6	42	187				limestone	27	187	
7. CASING, LINER, CURBING, AND SCREEN									
Dia. (in.)	Kind and Weight		From (ft.)	To (ft.)					
6	new black steel pipe		Surface						
	welded joints								
	18.97 bls. ASTM A53			42					
8. GROUT OR OTHER SEALING MATERIAL						10. TYPE OF DRILLING MACHINE USED			
Kind			From (ft.)	To (ft.)					
clear cement & water			Surface						
5 1/2 gals. to 1 bag				42					
11. MISCELLANEOUS DATA									
Yield test:		4 Hrs. at	15 GPM						
Depth from surface to normal water level		35 ft.							
Depth to water level when pumping		50 ft.							
Water sample sent to Madison						laboratory on: 3-10 19 76			

Your opinion concerning other pollution hazards, information concerning difficulties encountered, and data relating to nearby wells, screens, seals, type of casing joints, method of finishing the well, amount of cement used in grouting, blasting, sub-surface pumprooms, access pits, etc., should be given on reverse side.

SIGNATURE
Richard Roschi Registered Well Driller
COMPLETE MAIL ADDRESS
12665 W. Lisbon Rd. Brookfield, Wis. 53005

Please do not write in space below

COL		GAS - 24 HRS	GAS - 48 HRS.	CONFIRMED	REMARKS
REV	0 2 6 6 3 0				